



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.12	28.4			Y
2	8.10	29.1			Y
3	8.13	24.6			Y
4	8.16	26.4			Y
5	8.20	26.9			Y
6	8.24	26.0			Y
7	8.28	25.6			Y
8	8.26	26.6			Y
9	8.23	24.5			Y
10	8.24	24.6			Y
11	8.24	27.2			Y
12	8.22	26.1			Y
13	8.22	28.2			Y
14	8.20	26.1			Y
15	8.18	27.1			Y
16	8.16	26.5			Y
17	8.14	26.1			Y
18	8.11	24.5			Y
19	8.08	24.7			Y
20	8.10	27.9			Y
21	8.11	26.0			Y
22	8.12	25.0			Y
23	8.16	25.9			Y
24	8.18	24.9			Y
25	8.18	25.6			Y
26	8.14	22.2			Y
27	8.06	27.8			Y
28	8.09	25.4			Y
29	8.12	24.0			Y
30	8.11	28.3			Y
31	8.07	24.8			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: August 2024

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 9/6/24

Send to DWP within 10 days after end of sample period