



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.16	23.0			Y
2	8.16	27.5			Y
3	8.16	26.6			Y
4	8.14	25.3			Y
5	8.18	24.0			Y
6	8.18	23.0			Y
7	8.15	24.0			Y
8	8.11	24.1			Y
9	8.10	23.5			Y
10	8.11	OFF			Y
11	8.10	23.0			Y
12	8.11	23.7			Y
13	8.13	23.5			Y
14	8.11	22.5			Y
15	8.09	24.4			Y
16	8.08	24.5			Y
17	8.06	23.0			Y
18	8.08	25.4			Y
19	8.11	23.6			Y
20	8.09	23.7			Y
21	8.01	26.8			Y
22	7.97	24.3			Y
23	7.96	23.5			Y
24	7.98	26.6			Y
25	8.01	25.6			Y
26	8.03	29.2			Y
27	8.00	OFF			Y
28	7.99	25.3			Y
29	7.96	24.8			Y
30	8.01	25.6			Y
31	7.80	23.6			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: October 2024

Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 7.8

Alk 18.0 (Alkalinity)

PO<sub>4</sub>   (Orthophosphate)

Sili   (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 11/8/2024 541-704-2309