



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1		OFF			
2	7.73	24.5			N
3	8.03	22.3			Y
4	8.10	26.4			Y
5	8.14	26.0			Y
6	8.13	26.6			Y
7	8.15	24.3			Y
8	8.17	25.8			Y
9	8.19	24.0			Y
10	8.17	24.6			Y
11	8.09	25.0			Y
12	8.08	24.3			Y
13	8.08	24.7			Y
14	8.08	25.4			Y
15	8.05	24.2			Y
16	7.99	26.3			Y
17	7.96	26.4			Y
18	8.02	26.2			Y
19	8.06	25.1			Y
20	8.05	23.5			Y
21	8.06	22.8			Y
22	8.02	23.6			Y
23	7.96	23.4			Y
24	7.91	23.3			Y
25	7.92	23.0			Y
26	7.95	26.0			Y
27	8.01	24.5			Y
28	8.05	25.5			Y
29	8.10	23.6			Y
30	8.15	26.5			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: November 2024

Month/Year

Number of excursions* during this month: 1
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 12/9/24 541-704-2309

Send to DWP within 10 days after end of sample period