



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.32	19.3			Y
2	8.34	OFF			Y
3	8.23	OFF			Y
4	8.19	21.0			Y
5	8.31	24.4			Y
6	8.46	OFF			Y
7	8.48	25.1			Y
8	8.44	22.4			Y
9	8.37	22.8			Y
10	8.30	OFF			Y
11	8.33	22.8			Y
12	8.36	OFF			Y
13	8.37	21.7			Y
14	8.34	21.7			Y
15	8.21	21.9			Y
16	8.09	22.8			Y
17	8.00	19.3			Y
18	8.02	OFF			Y
19	8.07	OFF			Y
20	8.08	OFF			Y
21	8.09	OFF			Y
22	8.14	23.7			Y
23	8.14	22.5			Y
24	8.13	23.0			Y
25	8.19	24.1			Y
26	8.21	23.0			Y
27	8.18	OFF			Y
28	8.15	23.5			Y
29	8.05	23.6			Y
30	8.13	22.8			Y
31	8.18	24.3			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: March 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 4/8/25 541-704-2309

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405