



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.07	24.7			Y
2	8.22	22.6			Y
3	8.22	24.8			Y
4	8.24	25.8			Y
5	8.22	22.0			Y
6	8.21	26.9			Y
7	8.19	23.1			Y
8	8.05	23.5			Y
9	7.80	OFF			Y
10	7.80	OFF			Y
11	7.80	OFF			Y
12	7.80	OFF			Y
13	7.86	21.2			Y
14	8.18	26.3			Y
15	8.37	23.6			Y
16	8.35	22.0			Y
17	8.24	22.3			Y
18	8.27	22.8			Y
19	8.23	23.6			Y
20	8.18	23.6			Y
21	8.26	22.6			Y
22	8.28	24.5			Y
23	8.25	26.4			Y
24	8.21	23.6			Y
25	8.25	22.3			Y
26	8.28	21.8			Y
27	8.28	23.5			Y
28	8.30	OFF			Y
29	8.27	OFF			Y
30	8.19	OFF			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: April 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 1

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 541-704-2309

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405