



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.20	23.9			Y
2	8.23	21.9			Y
3	8.20	21.7			Y
4	8.22	24.5			Y
5	8.27	24.2			Y
6	8.25	23.1			Y
7	8.17	25.0			Y
8	8.17	22.6			Y
9	8.22	25.7			Y
10	8.18	OFF			Y
11	8.18	23.3			Y
12	8.18	25.6			Y
13	8.13	25.0			Y
14	8.13	24.4			Y
15	8.19	22.0			Y
16	8.20	OFF			Y
17	8.19	OFF			Y
18	8.23	OFF			Y
19	8.10	OFF			Y
20	7.83	OFF			Y
21	7.80	OFF			Y
22	7.82	21.8			Y
23	8.18	24.6			Y
24	8.18	21.8			Y
25	8.15	23.6			Y
26	8.05	24.3			Y
27	8.05	23.8			Y
28	8.10	21.7			Y
29	8.18	24.0			Y
30	8.19	21.0			Y
31	8.16	21.3			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: May 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 6/6/25 591-704-2309

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405