



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.15	22.8			Y
2	8.19	22.5			Y
3	8.17	23.3			Y
4	8.12	23.9			Y
5	8.09	22.9			Y
6	8.09	22.3			Y
7	8.05	21.6			Y
8	8.01	21.1			Y
9	8.03	25.5			Y
10	8.10	23.1			Y
11	8.14	22.3			Y
12	8.12	21.2			Y
13	8.14	23.6			Y
14	8.16	24.9			Y
15	8.14	21.5			Y
16	8.10	23.6			Y
17	8.09	22.6			Y
18	8.11	22.1			Y
19	8.07	21.9			Y
20	7.99	23.6			Y
21	7.99	20.2			Y
22	7.96	23.8			Y
23	7.86	21.4			Y
24	7.92	21.4			Y
25	7.97	22.1			Y
26	8.11	22.8			Y
27	8.18	22.6			Y
28	8.12	22.6			Y
29	8.09	23.6			Y
30	8.06	21.8			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: June 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 7-7-2025 541-704-2809

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405