



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.09	22.6			Y
2	8.10	25.9			Y
3	8.18	23.0			Y
4	8.23	24.0			Y
5	8.29	26.2			Y
6	8.26	23.8			Y
7	8.17	23.0			Y
8	8.08	22.8			Y
9	8.12	23.5			Y
10	8.10	22.6			Y
11	8.13	23.4			Y
12	8.19	23.8			Y
13	8.16	24.1			Y
14	8.10	24.1			Y
15	8.12	24.0			Y
16	8.13	25.5			Y
17	8.10	23.7			Y
18	8.11	24.5			Y
19	8.13	23.8			Y
20	8.10	21.9			Y
21	8.11	22.7			Y
22	8.01	22.9			Y
23	7.95	22.1			Y
24	7.88	22.6			Y
25	7.99	26.0			Y
26	8.07	25.4			Y
27	8.06	22.3			Y
28	8.09	26.8			Y
29	8.09	23.0			Y
30	8.07	23.8			Y
31	8.07	23.9			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: July 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 541-704-2309 8/6/25

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405