

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.06	25.0			Y
2	8.02	24.2			Y
3	8.03	24.1			Y
4	8.03	23.0			Y
5	7.95	21.6			Y
6	8.08	22.6			Y
7	8.09	22.9			Y
8	7.99	23.0			Y
9	8.00	24.4			Y
10	7.95	24.9			Y
11	7.93	23.0			Y
12	8.01	22.9			Y
13	8.07	23.5			Y
14	8.12	23.1			Y
15	8.13	24.1			Y
16	8.10	24.9			Y
17	8.05	23.8			Y
18	8.05	24.3			Y
19	8.08	23.9			Y
20	8.09	23.1			Y
21	8.06	23.4			Y
22	8.06	23.3			Y
23	7.99	23.0			Y
24	8.05	25.1			Y
25	8.03	23.9			Y
26	8.07	23.4			Y
27	8.04	24.0			Y
28	8.10	23.3			Y
29	8.09	23.5			Y
30	8.15	22.0			Y
31	8.13	24.5			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: August 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 9/8/25 541-709-2809

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405