



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.05	23.1			Y
2	8.02	23.1			Y
3	8.01	22.8			Y
4	7.98	23.0			Y
5	8.02	24.1			Y
6	8.02	24.4			Y
7	8.02	24.3			Y
8	8.04	21.9			Y
9	8.06	24.3			Y
10	8.04	23.7			Y
11	8.01	23.8			Y
12	8.04	24.4			Y
13	8.05	23.4			Y
14	8.02	22.3			Y
15	8.03	25.8			Y
16	8.02	25.8			Y
17	8.02	OFF			Y
18	8.10	24.4			Y
19	8.09	23.0			Y
20	8.08	22.6			Y
21	8.05	22.8			Y
22	8.02	24.0			Y
23	8.03	23.0			Y
24	7.99	22.3			Y
25	8.04	24.2			Y
26	8.12	25.4			Y
27	8.14	24.0			Y
28	8.13	OFF			Y
29	8.11	24.0			Y
30	8.12	23.0			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: AlbanyEntry Point: Vine Street Drinking Water PlantSample Period: September 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8Alk 18.0 (Alkalinity)PO₄ (Orthophosphate)Sili (Silicate)Print Name: Chris GermondSignature: Chris GermondDate & Phone#: 541-704-2309 10/3/25

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405