

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.08	21.7			Y
2	8.05	23.8			Y
3	8.07	22.5			Y
4	8.05	23.0			Y
5	8.00	OFF			Y
6	8.00	22.9			Y
7	8.04	24.0			Y
8	8.06	23.8			Y
9	8.10	24.1			Y
10	8.09	24.5			Y
11	8.08	24.2			Y
12	8.08	24.0			Y
13	8.07	22.8			Y
14	8.11	23.1			Y
15	8.10	25.0			Y
16	8.10	25.1			Y
17	8.05	25.1			Y
18	7.92	25.5			Y
19	7.89	24.9			Y
20	7.85	23.1			Y
21	7.86	25.3			Y
22	7.85	26.0			Y
23	7.80	26.2			Y
24	7.80	25.8			Y
25	7.86	26.0			Y
26	7.93	26.3			Y
27	7.99	26.0			Y
28	7.94	25.3			Y
29	7.87	27.3			Y
30	7.85	27.1			Y
31	7.92	27.8			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: October 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germund

Signature: Chris Germund

Date & Phone#: 11/6/25 541-709-2309

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405