



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.99	OFF			Y
2	7.99	OFF			Y
3	7.95	OFF			Y
4	7.95	26.8			Y
5	8.21	30.0			Y
6	8.30	27.4			Y
7	8.30	27.4			Y
8	8.28	26.1			Y
9	8.30	28.8			Y
10	8.30	19.0			Y
11	8.31	27.1			Y
12	8.32	27.4			Y
13	8.30	25.3			Y
14	8.31	26.5			Y
15	8.25	27.0			Y
16	8.21	26.8			Y
17	8.13	26.4			Y
18	8.25	25.8			Y
19	8.26	27.0			Y
20	8.24	26.8			Y
21	8.25	27.3			Y
22	8.25	26.1			Y
23	8.23	OFF			Y
24	8.20	25.9			Y
25	8.19	26.3			Y
26	8.23	27.2			Y
27	8.25	27.3			Y
28	8.26	28.1			Y
29	8.26	28.8			Y
30	8.26	OFF			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: November 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 12/8/25 541-704-2309

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405