

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.26	27.5			Y
2	8.27	OFF			Y
3	8.27	28.0			Y
4	8.26	OFF			Y
5	8.26	29.5			Y
6	8.26	29.8			Y
7	8.25	29.5			Y
8	8.28	29.4			Y
9	8.31	27.8			Y
10	8.28	27.1			Y
11	8.22	26.6			Y
12	8.16	25.2			Y
13	8.16	23.1			Y
14	8.17	20.2			Y
15	8.20	19.9			Y
16	8.23	21.9			Y
17	8.24	21.1			Y
18	8.22	22.0			Y
19	8.10	22.5			Y
20	8.01	22.7			Y
21	8.00	20.9			Y
22	8.04	21.2			Y
23	8.10	23.5			Y
24	8.18	24.0			Y
25	8.19	29.0			Y
26	8.24	23.3			Y
27	8.24	23.3			Y
28	8.23	24.7			Y
29	8.26	OFF			Y
30	8.24	OFF			Y
31	8.27	23.8			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: December 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 1/7/26 541-704-2309

Send to DWP within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405