



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.29	23.6			Y
2	8.23	24.3			Y
3	8.17	23.4			Y
4	8.14	21.9			Y
5	8.08	22.8			Y
6	8.01	24.9			Y
7	8.04	25.1			Y
8	8.05	25.3			Y
9	8.05	26.1			Y
10	8.07	24.3			Y
11	8.13	25.2			Y
12	8.18	26.0			Y
13	8.22	24.2			Y
14	8.25	25.0			Y
15	8.24	24.9			Y
16	8.24	24.0			Y
17	8.24	23.9			Y
18	8.22	OFF			Y
19	8.21	OFF			Y
20	8.22	OFF			Y
21	8.23	23.5			Y
22	8.29	24.4			Y
23	8.34	24.2			Y
24	8.30	24.5			Y
25	8.28	OFF			Y
26	8.24	23.0			Y
27	8.29	21.6			Y
28	8.29	24.1			Y
29	8.28	23.5			Y
30	8.24	24.1			Y
31	8.20	OFF			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: January 2026

Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 541-704-2301 2/7/26