



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.20	OFF			Y
2	8.21	22.7			Y
3	8.21	22.2			Y
4	8.23	22.8			Y
5	8.20	22.9			Y
6	8.18	23.3			Y
7	8.21	OFF			Y
8	8.20	OFF			Y
9	8.19	21.5			Y
10	8.18	OFF			Y
11	8.24	24.4			Y
12	8.18	24.5			Y
13	8.05	25.5			Y
14	8.13	24.3			Y
15	8.15	OFF			Y
16	8.16	24.8			Y
17	8.12	24.8			Y
18	8.08	27.8			Y
19	8.07	OFF			Y
20	8.10	OFF			Y
21	8.10	27.1			Y
22	8.11	OFF			Y
23	8.10	25.2			Y
24	8.03	25.7			Y
25	7.92	24.8			Y
26	7.92	30.3			Y
27	8.04	28.8			Y
28	8.17	28.3			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 A

System Name: Albany

Entry Point: Vine Street Drinking Water Plant

Sample Period: February 2026

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 3/4/26 591-704-2309