

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.30	19.4			Y
2	8.28	18.9			Y
3	8.27	20.5			Y
4	8.25	18.4			Y
5	8.16	19.6			Y
6	8.12	18.7			Y
7	8.10	19.6			Y
8	8.08	18.3			Y
9	8.13	16.5			N
10	8.22	24.3			Y
11	8.25	24.2			Y
12	8.30	23.2			Y
13	8.24	21			Y
14	8.07	23			Y
15	8.08	23.1			Y
16	8.05	20.9			Y
17	8.07	22.8			Y
18	8.15	23.3			Y
19	8.19	26			Y
20	8.23	24.5			Y
21	8.25	22.7			Y
22	8.27	21.6			Y
23	8.23	22.9			Y
24	8.22	22.6			Y
25	8.16	21.9			Y
26	8.21	21.7			Y
27	8.11	22			Y
28	8.09	22.7			Y
29	8.18	24.8			Y
30	8.16	25.5			Y
31	8.18	26.3			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: January 2021

Month/Year

Number of excursions\* during this month: 1

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**

Parameters as set by State:

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

1/9/21 Excursion - Reviewed for that day, day, before, day after. Rain Event the day before of 0.46", Raw Turbs. 13.9 + 23.6 NTU's, but settled out over next 24 hrs. Will monitor for ACH adjust and pH.

Print Name: Chuck Leffler

Signature: [Signature]

Date & Phone#: 2-3-21; 541-990-1907

Send to DHS within 10 days after end of sample period