

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.17	25.7			Y
2	8.12	26.7			Y
3	8.05	26			Y
4	8.09	25.8			Y
5	8.08	22.7			Y
6	8.22	26.4			Y
7	8.35	27.6			Y
8	8.32	28.8			Y
9	8.22	24.5			Y
10	8.17	25.6			Y
11	8.21	24.5			Y
12	8.18	25.8			Y
13	8.24	25.2			Y
14	8.39	24.6			Y
15	8.35	23			Y
16	8.43	21.1			Y
17	8.31	20			Y
18	8.10	23.1			Y
19	8.07	20.7			Y
20	8.18	23.4			Y
21	8.17	23.7			Y
22	8.14	21.1			Y
23	8.19	23			Y
24	8.23	24.1			Y
25	8.06	21.8			Y
26	8.26	24.1			Y
27	8.37	23.4			Y
28	8.36	22.9			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: February 2021
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature: 

Date & Phone#: 3-3-21, 541-990-1907