



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.23	22.3			Y
2	8.11	24.5			Y
3	8.13	26			Y
4	8.15	25.9			Y
5	8.16	23.1			Y
6	8.21	25.9			Y
7	8.21	23.4			Y
8	8.26	25.1			Y
9	8.29	26.7			Y
10	8.24	26.4			Y
11	8.14	25.9			Y
12	8.09	27.1			Y
13	8.14	27.7			Y
14	8.15	23.4			Y
15	8.13	23.9			Y
16	8.16	24.3			Y
17	8.10	28.6			Y
18	8.13	29.3			Y
19	8.17	28.9			Y
20	8.12	27.5			Y
21	8.18	25.1			Y
22	8.22	24.3			Y
23	8.20	27.1			Y
24	8.24	26.4			Y
25	8.23	25.8			Y
26	8.29	24.5			Y
27	8.24	25.6			Y
28	8.27	27.1			Y
29	8.27	25.1			Y
30	8.22	26.5			Y
31	8.18	25.7			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: May 2021

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Sean LaRoque, Water Superintendent

Signature: [Signature]

Date & Phone#: 6/10/21, 541 791 0175

Send to DHS within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405