

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.04	27.1			Y
2	8.02	26.2			Y
3	8.17	23.6			Y
4	7.86	22.9			Y
5	7.93	23.3			Y
6	8.08	27.3			Y
7	8.20	26.9			Y
8	8.27	26.1			Y
9	8.29	24			Y
10	8.26	23.4			Y
11	8.29	24.1			Y
12	8.31	25.1			Y
13	8.28	24.2			Y
14	8.13	25.7			Y
15	8.20	25.1			Y
16	8.19	24.2			Y
17	8.20	24.1			Y
18	8.17	24.4			Y
19	8.17	25.2			Y
20	8.15	25.2			Y
21	8.07	23.1			Y
22	8.04	26.8			Y
23	8.08	25.2			Y
24	8.12	25.7			Y
25	8.10	23.9			Y
26	8.04	23.8			Y
27	8.04	24.8			Y
28	8.08	26.1			Y
29	8.17	25.2			Y
30	8.19	24.1			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: June 2021

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:


pH

Alk (Alkalinity)

PO4 (Orthophosphosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature: 

Date & Phone#: 7-7-21, 541-990-1907