

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.18	24.2			Y
2	8.21	24.4			Y
3	8.21	25.9			Y
4	8.14	27.7			Y
5	8.13	24.2			Y
6	8.15	21.8			Y
7	8.15	24.1			Y
8	8.22	21.7			Y
9	8.29	22.4			Y
10	8.24	22.4			Y
11	8.17	25.1			Y
12	8.17	27.6			Y
13	8.20	22.3			Y
14	8.23	21.3			Y
15	8.20	25.4			Y
16	8.26	24.5			Y
17	8.25	26.4			Y
18	8.26	27.1			Y
19	8.24	25.1			Y
20	8.28	23.7			Y
21	8.30	28.4			Y
22	8.30	25.2			Y
23	8.31	22.6			Y
24	8.30	23.3			Y
25	8.28	24.2			Y
26	8.28	23.8			Y
27	8.29	22.4			Y
28	8.28	25.3			Y
29	8.20	22.7			Y
30	8.24	21.7			Y
31	8.26	24.6			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: July 2021

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck LaPfler

Signature: 

Date & Phone#: 8-9-21, 541-990-1907