

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.28	0			N
2	8.33	28.2			Y
3	8.34	24.2			Y
4	8.32	25.9			Y
5	8.26	24.9			Y
6	8.36	25.3			Y
7	8.22	23.1			Y
8	8.10	24.9			Y
9	8.21	23.2			Y
10	8.21	24.1			Y
11	8.16	25.5			Y
12	8.09	24.6			Y
13	8.14	24			Y
14	8.21	23.1			Y
15	8.20	26.5			Y
16	8.19	28			Y
17	8.14	27.8			Y
18	8.18	23.1			Y
19	8.17	25			Y
20	8.07	24.1			Y
21	8.10	24.9			Y
22	8.14	21.7			Y
23	8.19	24.6			Y
24	8.20	25.2			Y
25	8.19	27.4			Y
26	8.19	24.1			Y
27	8.15	25.3			Y
28	8.15	22.9			Y
29	8.14	20.9			Y
30	8.16	25.8			Y
31	8.16	23.8			Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**PWS ID: 4100012 B**  
**System Name: Albany**  
**Entry Point: AM Drinking Water Plant**  
**Sample Period: August 2021**  
Month/Year

**Number of excursions\* during this month: 1**

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 1**

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**  
**Parameters as set by State:**


pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

**Print Name:** Charles Lettler

**Signature:** 

**Date & Phone#:** 9-3-21, 541-990-1907