



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.15	23.7			Y
2	8.21	22.4			Y
3	8.26	24			Y
4	8.25	25.5			Y
5	8.22	26.2			Y
6	8.17	23.6			Y
7	8.16	24.7			Y
8	8.21	26.7			Y
9	8.20	22.7			Y
10	8.19	26.4			Y
11	8.18	24.2			Y
12	8.24	24.1			Y
13	8.23	24.6			Y
14	8.23	24.5			Y
15	8.24	24.1			Y
16	8.27	22.3			Y
17	8.30	25.8			Y
18	8.36	21.4			Y
19	8.14	22.5			Y
20	8.11	26.2			Y
21	8.14	23.8			Y
22	8.10	24.9			Y
23	8.17	25.9			Y
24	8.20	25.4			Y
25	8.14	25.3			Y
26	8.15	24.1			Y
27	8.17	23.7			Y
28	8.00	24.7			Y
29	8.10	24.7			Y
30	8.23	25.8			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: September 2021

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRocque, Water Superintendent

Signature:

Date & Phone#: 10/8/21