



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.21	26.1			Y
2	8.25	25.8			Y
3	8.24	26			Y
4	8.21	23.5			Y
5	8.19	27.6			Y
6	8.15	26.5			Y
7	8.19	25.6			Y
8	8.19	23.7			Y
9	8.25	23.9			Y
10	8.30	27.5			Y
11	8.14	22.9			Y
12	8.17	27			Y
13	8.20	24.7			Y
14	8.24	25.5			Y
15	8.20	23.2			Y
16	8.27	24.5			Y
17	8.17	27			Y
18	8.15	28			Y
19	8.14	27.1			Y
20	8.16	23.3			Y
21	8.14	23.6			Y
22	8.11	26.8			Y
23	8.04	27.4			Y
24	8.01	25.7			Y
25	8.10	25.2			Y
26	8.12	25.8			Y
27	8.09	21.6			Y
28	8.08	23.6			Y
29	8.09	23.2			Y
30	8.07	22.8			Y
31	8.07	26.4			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: October 2021

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chad Leffler

Signature: [Signature]

Date & Phone#: 541-990-1907, 11-10-21