

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.13	27			Y
2	8.15	24			Y
3	8.14	24.2			Y
4	8.15	24.8			Y
5	8.08	25			Y
6	8.11	23.1			Y
7	8.16	26.6			Y
8	8.18	25.5			Y
9	8.21	25.6			Y
10	8.16	25.9			Y
11	8.13	22.9			Y
12	7.96	24.2			Y
13	7.95	21.2			Y
14	7.98	23.1			Y
15	8.08	24.8			Y
16	8.12	22.8			Y
17	8.30	22.1			Y
18	8.44	22.4			Y
19	8.41	22.5			Y
20	8.42	22.3			Y
21	8.40	24.7			Y
22	8.38	24.7			Y
23	8.38	21.2			Y
24	8.32	24.5			Y
25	8.33	21.8			Y
26	8.32	21.6			Y
27	8.30	21.4			Y
28	8.28	22			Y
29	8.30	24.9			Y
30	8.31	18.6			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: November 2021

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature: 

Date & Phone#: 12-10-21 ; 541-990-1907