



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.29	22			Y
2	8.26	25.7			Y
3	8.33	23			Y
4	8.36	26			Y
5	8.33	22.9			Y
6	8.36	23.3			Y
7	8.29	23.8			Y
8	8.19	22.8			Y
9	8.14	24.1			Y
10	8.15	23.8			Y
11	8.23	22.5			Y
12	8.27	23.4			Y
13	8.13	21.5			Y
14	8.05	22			Y
15	8.07	23.7			Y
16	8.15	21.3			Y
17	8.23	22			Y
18	8.19	23.1			Y
19	8.19	21.5			Y
20	8.07	21.9			Y
21	7.97	20.9			Y
22	7.98	20			Y
23	8.07	21.1			Y
24	8.22	24.4			Y
25	8.20	20.4			Y
26	8.17	27.8			Y
27	8.21	21.4			Y
28	8.21	23.7			Y
29	8.21	21.7			Y
30	8.22	22.5			Y
31	8.15	22.5			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: December 2021

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphosphate)

Sili (Silicate)

Print Name: Chuck Lettler

Signature:

Date & Phone#: 1-6-22, 541-990-1907