



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.12	22.2			Y
2	8.17	28.6			Y
3	8.20	21.7			Y
4	8.12	20.9			Y
5	8.10	20.3			Y
6	8.20	21.3			Y
7	8.26	22.5			Y
8	8.26	22.3			Y
9	8.22	18.9			Y
10	8.17	20.4			Y
11	8.18	19.8			Y
12	8.26	22.4			Y
13	8.26	24			Y
14	8.35	23.7			Y
15	8.34	20.8			Y
16	8.31	20.4			Y
17	8.29	18.4			Y
18	8.29	18			N
19	8.31	27.6			Y
20	8.32	23.1			Y
21	8.32	20.1			Y
22	8.32	19			Y
23	8.21	21.2			Y
24	8.25	21.7			Y
25	8.18	24			Y
26	8.16	22			Y
27	8.16	23.7			Y
28	8.22	21.5			Y
29	8.20	24.2			Y
30	8.16	22.2			Y
31	8.12	21.8			Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**PWS ID: 4100012 B**  
**System Name: Albany**  
**Entry Point: AM Drinking Water Plant**  
**Sample Period: January 2022**  
Month/Year

**Number of excursions\* during this month: 0**  
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphosphate)

Sili  (Silicate)

**Print Name:** Chuck Leffler  
**Signature:**   
**Date & Phone#:** 2-4-22, 541-990-1907