



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.15	21.4			Y
2	8.06	23.6			Y
3	8.01	24.1			Y
4	8.23	25.4			Y
5	8.30	22.3			Y
6	8.26	24.1			Y
7	8.20	28.2			Y
8	8.18	25.8			Y
9	8.19	25.8			Y
10	8.17	23.6			Y
11	8.16	26.5			Y
12	8.24	23.8			Y
13	8.30	27.1			Y
14	8.32	26.4			Y
15	8.35	24			Y
16	8.38	24			Y
17	8.28	23			Y
18	8.27	25			Y
19	8.25	23.3			Y
20	8.28	25.4			Y
21	8.31	26.6			Y
22	8.24	23.9			Y
23	8.25	25.5			Y
24	8.22	22.6			Y
25	8.22	24.9			Y
26	8.22	20.2			Y
27	8.31	27			Y
28	8.20	24.9			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: February 2022

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuch Koffler

Signature:

Date & Phone#: 3/9/22 ; 541-990-1907