

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|------|------|------|------|-----|
| 1 | 8.07 | 23.3 | | | Y |
| 2 | 8.14 | 22.1 | | | Y |
| 3 | 8.11 | 22.6 | | | Y |
| 4 | 8.07 | 21.1 | | | Y |
| 5 | 8.13 | 23.1 | | | Y |
| 6 | 8.03 | 21.6 | | | Y |
| 7 | 8.00 | 21.5 | | | Y |
| 8 | 8.05 | 22.7 | | | Y |
| 9 | 8.15 | 24.8 | | | Y |
| 10 | 8.17 | 22.3 | | | Y |
| 11 | 8.18 | 24.7 | | | Y |
| 12 | 8.20 | 33.6 | | | Y |
| 13 | 8.22 | 24.9 | | | Y |
| 14 | 8.07 | 24.7 | | | Y |
| 15 | 8.17 | 25.3 | | | Y |
| 17 | 8.33 | 23.3 | | | Y |
| 18 | 8.38 | 24 | | | Y |
| 19 | 8.41 | 23.3 | | | Y |
| 20 | 8.20 | 22.8 | | | Y |
| 21 | 8.20 | 22.8 | | | Y |
| 22 | 8.22 | 24.6 | | | Y |
| 23 | 8.27 | 24.6 | | | Y |
| 24 | 8.25 | 23 | | | Y |
| 25 | 8.33 | 23.5 | | | Y |
| 26 | 8.41 | 25.6 | | | Y |
| 27 | 8.38 | 27.3 | | | Y |
| 28 | 8.25 | 24.4 | | | Y |
| 29 | 8.18 | 25.3 | | | Y |
| 30 | 8.28 | 22.9 | | | Y |
| 31 | 8.29 | 24.8 | | | Y |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: March 2022

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature: 

Date & Phone#: 4-7-22, 541-990-1907