



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.31	24.1			Y
2	8.32	23.3			Y
3	8.24	22.6			Y
4	8.28	25.5			Y
5	8.29	24.7			Y
6	8.32	21.4			Y
7	8.27	23.4			Y
8	8.18	24.1			Y
9	8.13	26.5			Y
10	8.19	27.5			Y
11	8.19	22.2			Y
12	8.13	22.9			Y
13	7.99	25.8			Y
14	7.99	22.2			Y
15	8.28	23			Y
16	8.38	23.9			Y
17	8.28	22.4			Y
18	8.32	25.3			Y
19	8.11	23.7			Y
20	8.11	22.5			Y
21	8.00	24.5			Y
22	8.03	25.2			Y
23	8.20	24.8			Y
24	8.26	25.2			Y
25	8.18	22.2			Y
26	8.09	21.8			Y
27	8.17	22.8			Y
28	8.18	23.4			Y
29	8.16	24.2			Y
30	8.18	23.6			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: April 2022

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Loeffler

Signature:

Date & Phone#: 5-6-22, 541-990-1907