



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.34	24.3			Y
2	8.23	25.3			Y
3	8.20	25			Y
4	8.20	24.5			Y
5	8.19	21.5			Y
6	8.20	26.4			Y
7	8.21	23.9			Y
8	8.23	23.4			Y
9	8.20	22.4			Y
10	8.25	24.8			Y
11	8.26	23.9			Y
12	8.13	24.1			Y
13	8.13	21.5			Y
14	8.17	22.5			Y
15	8.12	23.5			Y
16	8.11	23.1			Y
17	8.13	24.6			Y
18	8.14	23.5			Y
19	8.17	22.5			Y
20	8.19	23.7			Y
21	8.17	22.5			Y
22	8.09	24.3			Y
23	8.06	24.7			Y
24	8.15	24.8			Y
25	8.15	24.4			Y
26	8.04	25			Y
27	8.02	26.5			Y
28	8.07	24.8			Y
29	8.20	22.5			Y
30	8.22	25.9			Y

<<Have minimums been met for this day?

ENTRY POINT
PWS ID: 4100012 B
System Name: Albany
Entry Point: AM Drinking Water Plant
Sample Period: June 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality
Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphosphate)

Sili (Silicate)

Print Name: Chuck Loffler
Signature: [Signature]
Date & Phone#: 7-7-22, 541-990-1907