

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.23	26			Y
2	8.15	26.1			Y
3	8.22	25.5			Y
4	8.29	26.9			Y
5	8.30	25.4			Y
6	8.17	29.7			Y
7	8.19	22.5			Y
8	8.25	26.1			Y
9	8.24	26			Y
10	8.19	26			Y
11	8.14	26.8			Y
12	8.08	27.3			Y
13	8.14	26.5			Y
14	8.17	28			Y
15	8.19	27.3			Y
16	8.22	28.2			Y
17	8.30	25.9			Y
18	8.31	25.4			Y
19	8.30	25.3			Y
20	8.26	26			Y
21	8.23	27.2			Y
22	8.26	26.4			Y
23	8.30	27.1			Y
24	8.35	25.1			Y
25	8.31	25.2			Y
26	8.23	24			Y
27	8.26	27.9			Y
28	8.27	26.2			Y
29	8.22	26.8			Y
30	8.18	25.2			Y
31	8.19	24.3			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: July 2022

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chuck Leffler

Signature: 

Date & Phone#: 8-10-22, 541-990-1907