

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH   | Alk  | Phos | Sili | Y/N |
|-----|------|------|------|------|-----|
| 1   | 8.28 | 24.9 |      |      | Y   |
| 2   | 8.33 | 25   |      |      | Y   |
| 3   | 8.31 | 24.7 |      |      | Y   |
| 4   | 8.32 | 27.4 |      |      | Y   |
| 5   | 8.33 | 25.2 |      |      | Y   |
| 6   | 8.36 | 25.8 |      |      | Y   |
| 7   | 8.34 | 29.1 |      |      | Y   |
| 8   | 8.33 | 23.9 |      |      | Y   |
| 9   | 8.37 | 26.4 |      |      | Y   |
| 10  | 8.41 | 25.9 |      |      | Y   |
| 11  | 8.38 | 26   |      |      | Y   |
| 12  | 8.39 | 25.5 |      |      | Y   |
| 13  | 8.26 | 27   |      |      | Y   |
| 14  | 8.25 | 24.6 |      |      | Y   |
| 15  | 8.22 | 26.9 |      |      | Y   |
| 16  | 8.16 | 26.6 |      |      | Y   |
| 17  | 8.14 | 22.9 |      |      | Y   |
| 18  | 8.19 | 27   |      |      | Y   |
| 19  | 8.23 | 25.5 |      |      | Y   |
| 20  | 8.28 | 24.1 |      |      | Y   |
| 21  | 8.25 | 23.2 |      |      | Y   |
| 22  | 8.24 | 23.4 |      |      | Y   |
| 23  | 8.18 | 24.4 |      |      | Y   |
| 24  | 8.21 | 23.8 |      |      | Y   |
| 25  | 8.21 | 24.5 |      |      | Y   |
| 26  | 8.21 | 24.6 |      |      | Y   |
| 27  | 8.17 | 26.3 |      |      | Y   |
| 28  | 8.24 | 23.6 |      |      | Y   |
| 29  | 8.28 | 23.1 |      |      | Y   |
| 30  | 8.26 | 22.9 |      |      | Y   |
| 31  | 8.22 | 24.9 |      |      | Y   |

<<Have minimums been met for this day?

**ENTRY POINT**  
**PWS ID: 4100012 B**  
**System Name: Albany**  
**Entry Point: AM Drinking Water Plant**  
**Sample Period: August 2022**  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**  
**Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

Print Name: Chuck Goffler  
 Signature: [Signature]  
 Date & Phone#: 9-2-22, 541-990-1907