



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.24	26.1			Y
2	8.29	25.3			Y
3	8.29	24.3			Y
4	8.27	25.8			Y
5	8.35	21.7			Y
6	8.34	25.2			Y
7	8.31	21.8			Y
8	8.36	25.4			Y
9	8.39	24.9			Y
10	8.36	24.5			Y
11	8.37	23			Y
12	8.32	25.5			Y
13	8.26	26			Y
14	8.21	23.9			Y
15	8.19	25.7			Y
16	8.24	23			Y
17	8.26	26.7			Y
18	8.29	22			Y
19	8.25	23.3			Y
20	8.26	21.8			Y
21	8.29	24			Y
22	8.28	24.5			Y
23	8.23	24.7			Y
24	8.24	24.5			Y
25	8.24	21.7			Y
26	8.24	22.7			Y
27	8.23	23.4			Y
28	8.21	22.1			Y
29	8.21	25.8			Y
30	8.16	23.9			Y

<<Have minimums been met for this day?

ENTRY POINT
PWS ID: 4100012 B
System Name: Albany
Entry Point: AM Drinking Water Plant
Sample Period: September 2022
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chandra Leffler

Signature: [Handwritten Signature]

Date & Phone#: 10-5-22 ; 541-990-1907

Send to DHS within 10 days after end of sample period