

## Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.19	23.3			Y
2	8.26	24.7			Y
3	8.19	22			Y
4	8.19	23.8			Y
5	8.16	27.2			Y
6	8.13	24.8			Y
7	8.12	25.5			Y
8	8.16	21.3			Y
9	8.07	22.7			Y
10	8.10	24			Y
11	8.17	23.8			Y
12	8.12	23.1			Y
13	8.20	23.6			Y
14	8.23	22.7			Y
15	8.23	26			Y
16	8.26	22.9			Y
17	8.30	23.9			Y
18	8.23	24.2			Y
19	8.22	23.8			Y
20	8.17	22.8			Y
21	8.26	25.3			Y
22	8.23	25.1			Y
23	8.29	23.2			Y
24	8.29	21.3			Y
25	8.24	21			Y
26	8.22	22.1			Y
27	8.24	20.9			Y
28	8.29	20.7			Y
29	8.18	25.3			Y
30	8.21	21.5			Y
31	8.18	23.1			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: October 2022

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4   (Orthophosphosphate)

Sili   (Silicate)

Print Name: Chuck Lettler

Signature:

Date & Phone#: 11-8-22, 541-990-1907