

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.11	25.1			Y
2	8.16	22.1			Y
3	8.25	23			Y
4	8.37	24.9			Y
5	8.32	26.1			Y
6	8.06	24.2			Y
7	8.03	18.5			Y
8	8.00	19			Y
9	7.99	20			Y
10	8.06	25			Y
11	8.06	22.4			Y
12	8.08	24			Y
13	8.08	23.2			Y
14	8.07	23.9			Y
15	8.10	23.5			Y
16	8.22	22.7			Y
17	8.27	25.2			Y
18	8.32	22.9			Y
19	8.34	24.5			Y
20	8.33	22.3			Y
21	8.36	21.8			Y
22	8.31	22.2			Y
23	8.25	22			Y
24	8.27	25.5			Y
25	8.20	24			Y
26	8.21	25.2			Y
27	8.26	25			Y
28	8.23	22.8			Y
29	8.25	23.2			Y
30	8.24	21.1			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: November 2022  
 Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**

Parameters as set by State:

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

Print Name: Chuck Leffler

Signature: [Signature]

Date & Phone#: 12-9-22, 541-990-1907