

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.04	25.1			Y
2	8.07	25			Y
3	8.12	21.6			Y
4	8.06	23			Y
5	8.01	22.3			Y
6	7.85	22.6			Y
7	7.99	24.5			Y
8	7.98	25.3			Y
9	8.05	27			Y
10	8.15	23.5			Y
11	8.28	21.6			Y
12	8.30	3.1			N
13	8.28	21.8			Y
14	8.22	24.3			Y
15	8.23	24.9			Y
16	8.24	21.6			Y
17	8.16	22.5			Y
18	8.11	22.5			Y
19	8.10	22.6			Y
20	8.00	24.9			Y
21	8.17	23.1			Y
22	8.44	24.3			Y
23	8.49	23.4			Y
24	8.42	23.4			Y
25	8.32	25.2			Y
26	8.21	19.5			Y
27	8.24	19.9			Y
28	8.06	18.7			Y
29	8.01	22.7			Y
30	7.98	23.7			Y
31	8.08	24.2			Y

<<Have minimums been met for this day?

ENTRY POINT
PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: December 2022
Month/Year

Number of excursions* during this month: 1

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chad LeBlanc

Signature: [Signature]

Date & Phone#: 1-5-23, 501-990-1907