



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.21	22.9			Y
2	8.26	26.9			Y
3	8.30	23			Y
4	8.36	22.4			Y
5	8.32	24.9			Y
6	8.31	27			Y
7	8.30	25			Y
8	8.19	25.3			Y
9	8.15	20.3			Y
10	8.14	23.8			Y
11	8.12	24.5			Y
12	8.03	25			Y
13	8.11	25.2			Y
14	8.11	24.5			Y
15	8.21	25.5			Y
16	8.23	26.2			Y
17	8.18	24.1			Y
18	8.10	22.1			Y
19	8.24	25.5			Y
20	8.27	27.7			Y
21	8.24	29			Y
22	8.24	26.5			Y
23	8.23	23.3			Y
24	8.15	21.2			Y
25	7.85	22.6			Y
26	8.12	27.3			Y
27	8.13	26.1			Y
28	8.09	27.1			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

---

Sample Period: February 2023

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**

Parameters as set by State:

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

Print Name: Scott LaRogue

Signature: [Signature]

Date & Phone#: 3/10/23, 541 791 0175