



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.05	25			Y
2	8.01	25.8			Y
3	7.90	24.1			Y
4	8.08	27.7			Y
5	8.02	25.2			Y
6	8.06	27.3			Y
7	8.14	27.4			Y
8	8.06	28.7			Y
9	8.11	24.7			Y
10	8.08	26.2			Y
11	8.10	26.5			Y
12	8.11	26.5			Y
13	8.31	26.3			Y
14	8.00	27.4			Y
15	8.28	26.2			Y
16	8.45	25.2			Y
17	8.29	25.7			Y
18	8.23	21.4			Y
19	8.16	25.9			Y
20	8.15	26.6			Y
21	8.28	24.9			Y
22	8.36	25			Y
23	8.33	22.4			Y
24	8.27	24.9			Y
25	8.26	25.1			Y
26	8.26	24.6			Y
27	8.24	24.4			Y
28	8.34	24.7			Y
29	8.37	25.3			Y
30	8.38	23.3			Y
31	8.22	18.4			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: March 2023

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Jean LaRoque

Signature: [Handwritten Signature]

Date & Phone#: 4/7/2023, 541 791 0175

Send to DHS within 10 days after end of sample period