



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.24	21.5			Y
2	8.17	21.8			Y
3	8.14	20.2			Y
4	8.10	18.4			Y
5	8.13	21.9			Y
6	8.17	19.5			Y
7	8.14	22			Y
8	8.15	22.7			Y
9	8.20	22.2			Y
10	8.13	22.1			Y
11	8.07	21.5			Y
12	8.06	19.8			Y
13	8.02	21			Y
14	7.79	21.5			Y
15	8.15	23.6			Y
16	8.38	21.3			Y
17	8.20	22.3			Y
18	8.06	22.8			Y
19	8.09	21.5			Y
20	8.05	20.7			Y
21	7.92	22			Y
22	8.13	22.6			Y
23	8.43	22.2			Y
24	8.48	21.1			Y
25	8.41	22.2			Y
26	8.24	19.7			Y
27	8.22	19.4			Y
28	8.23	22			Y
29	8.22	21.5			Y
30	8.22	22			Y
31	8.29	22.1			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: May 2023

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRoque

Signature: [Signature]

Date & Phone#: 6/6/23, 541 791 0175