



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.33	23.7			Y
2	8.28	24.1			Y
3	8.25	23.4			Y
4	8.22	23.8			Y
5	8.22	22.9			Y
6	8.15	22			Y
7	8.06	22.6			Y
8	8.10	24.2			Y
9	8.17	21.1			Y
10	8.24	21.4			Y
11	8.16	23.8			Y
12	8.14	22			Y
13	8.02	23			Y
14	8.03	22.3			Y
15	8.14	23.3			Y
16	8.13	22.9			Y
17	7.89	22.4			Y
18	7.99	24.2			Y
19	8.24	23.2			Y
20	8.60	23.4			Y
21	8.70	26.5			Y
22	8.45	24.3			Y
23	8.27	23.8			Y
24	8.29	24			Y
25	8.28	25.5			Y
26	8.17	25.2			Y
27	8.23	25.5			Y
28	8.26	23.9			Y
29	8.21	23.3			Y
30	8.17	25.8			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: June 2023

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: SCOTT CAROQUE

Signature:

Date & Phone#: 7/6/23, 511 741 0175