



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.18	22.6			Y
2	8.14	28			Y
3	8.08	24.1			Y
4	8.09	25.2			Y
5	8.08	24.2			Y
6	8.08	22.7			Y
7	8.12	23.4			Y
8	8.22	22.7			Y
9	8.30	24.8			Y
10	8.23	25.9			Y
11	8.27	23.9			Y
12	8.22	24.6			Y
13	8.54	24.7			Y
14	8.44	23.3			Y
15	8.31	24.3			Y
16	8.31	25.4			Y
17	8.37	23.4			Y
18	8.54	22.4			Y
19	8.40	21.9			Y
20	8.35	20.8			Y
21	8.36	21.2			Y
22	8.44	21.7			Y
23	8.40	22.2			Y
24	8.40	25.3			Y
25	8.45	22.7			Y
26	8.41	21			Y
27	8.37	24.1			Y
28	8.42	21.9			Y
29	8.49	23.4			Y
30	8.52	21.5			Y
31	8.54	22.7			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: July 2023

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: SCOTT LaRoque

Signature: [Handwritten Signature]

Date & Phone#: 8/9/23, 541791 0175