



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.55	22.5			Y
2	8.51	21.2			Y
3	8.51	21.6			Y
4	8.48	24.8			Y
5	8.46	21.1			Y
6	8.49	20.8			Y
7	8.44	24.7			Y
8	8.36	23.7			Y
9	8.30	20.2			Y
10	8.32	23.3			Y
11	8.26	23.9			Y
12	8.28	24.3			Y
13	8.27	22.7			Y
14	8.31	26.6			Y
15	8.28	23			Y
16	8.28	20.6			Y
17	8.21	22.5			Y
18	8.20	22.2			Y
19	8.23	22.3			Y
20	8.25	22.9			Y
21	8.24	21			Y
22	8.19	23.1			Y
23	8.14	22.1			Y
24	8.18	20.5			Y
25	8.17	20.3			Y
26	7.95	19.3			Y
27	8.07	22.9			Y
28	8.09	22.3			Y
29	8.00	23.8			Y
30	8.13	24.8			Y
31	8.06	19.5			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: August 2023

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 9/8/2023 541-704-2309