



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.04	19.7			Y
2	8.05	19.6			Y
3	7.99	25.6			Y
4	8.05	23.7			Y
5	8.06	26			Y
6	8.07	22.2			Y
7	8.07	22.3			Y
8	8.16	20.8			Y
9	8.17	21.4			Y
10	8.19	22.8			Y
11	8.19	23.1			Y
12	8.22	24.6			Y
13	8.22	21.3			Y
14	8.22	22.2			Y
15	8.16	23			Y
16	8.11	22.9			Y
17	8.17	21.3			Y
18	8.12	22.2			Y
19	8.15	23.2			Y
20	8.14	22			Y
21	8.16	19.3			Y
22	8.17	20			Y
23	8.19	20.2			Y
24	8.21	23.3			Y
25	8.17	25.1			Y
26	8.17	22.1			Y
27	8.21	24.4			Y
28	8.20	22			Y
29	8.19	20.7			Y
30	8.17	21.5			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: September 2023

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 10/4/2023 591-704-309