



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.20	24.4			Y
2	8.20	23.8			Y
3	8.18	21.1			Y
4	8.18	22			Y
5	8.15	22.4			Y
6	8.11	21.5			Y
7	8.09	24.2			Y
8	8.15	25.2			Y
9	8.18	20.4			Y
10	8.16	24.2			Y
11	8.15	25.5			Y
12	8.11	23.4			Y
13	8.05	23			Y
14	8.05	22.9			Y
15	8.04	24.4			Y
16	8.03	24.1			Y
17	7.91	24.5			Y
18	8.02	27.4			Y
19	8.02	24.8			Y
20	8.01	26.1			Y
21	7.99	27.8			Y
22	8.01	24.5			Y
23	8.07	26.8			Y
24	8.10	26.9			Y
25	8.09	25.1			Y
26	8.13	25.5			Y
27	8.12	25.1			Y
28	8.16	28.1			Y
29	8.18	28.2			Y
30	8.16	24.8			Y
31	8.20	25.6			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: October 2023

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 11/8/23 541-704-2309