



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.15	25.1			Y
2	8.01	28			Y
3	8.02	25.6			Y
4	8.01	27			Y
5	8.03	25.9			Y
6	7.95	23.4			Y
7	7.86	27.7			Y
8	7.80	22.8			Y
9	8.09	24.6			Y
10	8.14	25			Y
11	8.14	24.4			Y
12	8.17	22			Y
13	8.20	24.6			Y
14	8.18	24.8			Y
15	8.10	25			Y
16	8.11	23.9			Y
17	8.10	24.1			Y
18	8.18	27			Y
19	8.15	26.5			Y
20	8.15	23.2			Y
21	8.16	22.3			Y
22	8.17	24.4			Y
23	8.15	24.1			Y
24	8.16	26.8			Y
25	8.16	27.8			Y
26	8.06	22.5			Y
27	8.06	26.2			Y
28	8.03	23.3			Y
29	8.02	23.3			Y
30	8.00	26.8			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: November 2023

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 541-704-2309 12/7/23