

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.18	23.2			Y
2	8.20	25.5			Y
3	8.18	22.9			Y
4	8.08	24.5			Y
5	8.11	24.4			Y
6	8.20	23.5			Y
7	8.14	20.2			Y
8	8.15	21.3			Y
9	8.17	20.7			Y
10	8.15	21.1			Y
11	8.10	20			Y
12	8.10	21.9			Y
13	8.17	21			Y
14	8.20	19.7			Y
15	8.18	18.4			Y
16	8.15	19.1			Y
17	8.10	23.5			Y
18	8.12	19			Y
19	8.09	23.8			Y
20	8.13	18.5			Y
21	8.16	18.3			Y
22	8.12	18.01			Y
23	8.13	18.01			Y
24	OFF				
25	10.36				N
26	8.50				Y
27	8.03	21.5			Y
28	8.08	18.6			Y
29	8.01	19.5			Y
30	7.84	24.2			Y
31	8.12	19.8			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: January 2024

Month/Year

Number of excursions* during this month: 1
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 2/9/24 591-269-2309