



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.13	20.1			Y
2	8.12	21.9			Y
3	8.12	20.2			Y
4	8.11	21.7			Y
5	8.10	22			Y
6	8.14	23			Y
7	8.14	24.1			Y
8	8.19	26.2			Y
9	8.18	22.1			Y
10	8.20	23.1			Y
11	8.22	22.7			Y
12	8.16	22.4			Y
13	8.16	23			Y
14	8.21	22.1			Y
15	8.28	23.8			Y
16	8.24	21.4			Y
17	8.18	20.4			Y
18	8.15	25.2			Y
19	8.19	20.2			Y
20	8.25	22.6			Y
21	8.28	23.5			Y
22	8.20	19.8			Y
23	8.14	26.3			Y
24	8.17	23			Y
25	8.17	19.5			Y
26	8.16	19.2			Y
27	8.19	22.3			Y
28	8.10	24			Y
29	8.12	21.5			Y
30	8.15	23.5			Y
31	8.17	20.7			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: March 2024

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Scott LaRoche

Signature: [Signature]

Date & Phone#: 4/4/24, 541 570 5719