



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.15	20.6			Y
2	8.16	19.2			Y
3	8.15	19.9			Y
4	8.16	20			Y
5	8.13	20.1			Y
6	8.13	26.3			Y
7	8.17	21.3			Y
8	8.16	21.1			Y
9	8.21	20.3			Y
10	8.20	21.3			Y
11	8.21	23.5			Y
12	8.21	25.1			Y
13	8.16	22.5			Y
14	8.13	21			Y
15	8.15	20			Y
16	8.12	21.5			Y
17	8.19	20			Y
18	8.25	23			Y
19	8.27	22.8			Y
20	8.23	23.5			Y
21	8.23	20.6			Y
22	8.24	19.7			Y
23	8.22	20.4			Y
24	8.21	23.2			Y
25	8.17	23			Y
26	8.10	23.5			Y
27	8.12	23			Y
28	8.11	19.3			Y
29	8.14	18.3			Y
30	8.18	22.6			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: April 2024

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 5/9/2024 541-990-0748