



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.09	18			Y
2	8.08	22.5			Y
3	8.02	19.5			Y
4	8.08	22.9			Y
5	7.96	19.6			Y
6	8.03	19.8			Y
7	8.08	21.7			Y
8	8.10	19.4			Y
9	8.10	21			Y
10	8.07	23			Y
11	8.03	20.8			Y
12	8.04	22.2			Y
13	8.07	20.2			Y
14	8.10	23.9			Y
15	8.02	23.5			Y
16	7.99	23.3			Y
17	8.02	27.8			Y
18	8.07	23			Y
19	8.09	23.7			Y
20	8.12	23.2			Y
21	8.14	24.5			Y
22	8.16	24.5			Y
23	8.20	24.4			Y
24	8.12	23.9			Y
25	8.15	22.4			Y
26	8.22	22.3			Y
27	8.22	24			Y
28	8.26	24.7			Y
29	8.34	26.1			Y
30	8.29	22.2			Y
31	8.24	25.2			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: May 2024

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 6/7/2024 591-209-2309