



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.25	22			Y
2	8.26	21.5			Y
3	8.26	20			Y
4	8.20	18.4			Y
5	8.16	20.1			Y
6	8.18	25.6			Y
7	8.18	21.5			Y
8	8.21	27.9			Y
9	8.19	18.5			Y
10	8.17	22.7			Y
11	8.16	19.5			Y
12	8.13	25.8			Y
13	8.07	24.8			Y
14	8.11	25.1			Y
15	8.22	25.9			Y
16	8.09	26.1			Y
17	8.03	24.2			Y
18	8.14	25.7			Y
19	8.04	24.8			Y
20	8.00	25.5			Y
21	7.98	27.7			Y
22	7.99	25.5			Y
23	7.99	21.5			Y
24	8.14	24.1			Y
25	8.05	21.1			Y
26	8.00	24.8			Y
27	8.21	25.9			Y
28	8.26	26.3			Y
29	8.10	27.8			Y
30	8.07	21			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: June 2024

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 7/3/2024 T-08682